Electric Outages Lewes BPW

Month	Date	Circuit	Customers Interrupted	Duration	Cause	Percent System Reliability
January 2019	1/02/2019 1/17/2019 1/26/2019	1 1 4	8 900 1	20 30 30	Squirrel Tree Squirrel	99.98385%
February 2019	2/4/19	1	4	30	Squirrel	99.99992%